



GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIVISIONAL FIRE OFFICER
PURULIA & BANKURA DIVISION
1ST. FLOOR, PURULIA F.S. RANCHI ROAD, PURULIA

Memo No. FES/PB/NOC/ 248 /2017

Dated: 20 / 06 /2017

**From : The Divisional Fire Officer,
Purulia & Bankura Division,
West Bengal Fire & Emg.Services.**

**To : The Chairman,
Swaraswatidevi International School,
Puabagan- Damodarpur,
Khatra- Daldanga Road
Dist. - Bankura.**

Sub : Issuance of Fire Safety Certificate of an existing G+III storied Educational building under group Educational, Sub- Division B-1, one number of G+III storied (Girls Hostel) residential Building, Sub-Division A-3 Dormitories and one number of G+II storied (Administrative) Business Building, Sub-Division E-1, as per the N.B.C of India 2005, by named & style as SWARASWATIDEVI INTERNATIONAL SCHOOL, on Mouza – Damodarpur, over Plot nos. 70, 371, 372, 373, 374, 375 & 377, JL no. 184, Kh no. 1207, and Mouza- Manjura , Plot nos. – 17, 18, 20, 4/185, 23/191, P.S. & Dist- Bankura.

**Ref : i) This Department Previous Memo No.
FES/PB/NOC/168/2017 Dated 11-05-2017.**

ii) His application dated 19/06/2017.

With reference to the above the undersigned has no objection to issue Fire safety certificate for the above mentioned buildings from the fire & life safety point of view in exercise of the power conferred to by Sub-Rule (2) of Rule 16 of W.B.F.S. (Fire prevention and Fire safety) Rules 1996 with up to date amendment as it fulfills the conditions laid down in clause 1 to 5 and or Sub-clause (a) to (o) of clause (6) of Rule 19 of W.B.F.S. (Fire Prevention and Fire safety Rules 1996 with up to date amendment and the relevant portions of Part IV of the N.B.C., I.S. Specification and relevant building Rules of Local Bodies, Subject to inspection report of The Inspecting Authority of this department and fulfillment of the residual Recommendations, issued vide this office no. as depicted above within or by 90 days from this date.

To keep up the fire safety installations /measures of the building(s), The following conditions shall be enforced:-

CONDITION APPLIED

1. Maintenance/checking /testing of all fire safety installations shall be checked time to time.
2. Any nominated officer of this deptt. Shall enter and inspect the building at any time between sunrise to sunset for ascertaining the contravention if any of Fire prevention and fire safety measures.
3. Good housekeeping should be always to be maintained.
4. Mock Drill must be performed twice in a year and recorded properly.
5. Violation of any recommendations which issued from this office vide no. as depicted above this certificate shall be treated as cancelled.

This certificate shall remain valid up to One year and will be renewed every year within the date of expiry.

PRINCIPAL

SARASWATI DEVI INTERNATIONAL SCHOOL
AFFILIATION NO. : 2430231 SCHOOL CODE : 15702
PUABAGAN :: DAMODARPUR :: BANKURA
WEST BENGAL :: PIN - 722146

SCHOOL MANAGER

SARASWATI DEVI INTERNATIONAL SCHOOL
AFFILIATION NO. : 2430231 SCHOOL CODE : 15702
PUABAGAN :: DAMODARPUR :: BANKURA
WEST BENGAL :: PIN - 722146

Divisional Fire Officer

**Purulia & Bankura Division
West Bengal Fire & Emg.Services**

**GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIVISIONAL FIRE OFFICER
WEST BENGAL FIRE & EMERGENCY SERVICES
P.O. - Kenduadihi, P.S. - Bankura, Pin - 722102**

Memo No : IND/WB/FES/20182019/40962

DATE: 02/02/2019

From :

**The Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services.**

To :

Swaraswatidevi International School.

**Puabagan-Damodarpur, Plot no. 70, 371 to 377, J.L no. 184, Kh. no. 1207, P.S & Dist.
Bankura, Pin - 722146.
Bankura F.S., Bankura P.S.,
Bankura - 722146 .**

**Sub :Renewal of Fire Safety Certificate for the occupancy of an existing construction
of G + 1 storied building under group Educational at the premises no.- Puabagan-
Damodarpur, Plot no. 70, 371 to 377, J.L no. 184, Kh. no. 1207, P.S & Dist. Bankura, Pin
- 722146., Bankura P.S., Bankura - 722146**

This is in reference to your Application No. IND/WB/FES/20182019/40962, dated 02/02/2019, regarding the Renewal of Fire Safety Certificate for the occupancy of an existing construction of G + 1 storied building under group Educational at the premises no.- Puabagan-Damodarpur, Plot no. 70, 371 to 377, J.L no. 184, Kh. no. 1207, P.S & Dist. Bankura, Pin - 722146., Bankura P.S., Bankura - 722146.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.


**PRINCIPAL
SARASWATI DEVI INTERNATIONAL SCHOOL
AFFILIATION NO. : 2430231 SCHOOL CODE : 15702
PUABAGAN :: DAMODARPUR :: BANKURA
WEST BENGAL :: PIN - 722146**


**SCHOOL MANAGER
SARASWATI DEVI INTERNATIONAL SCHOOL
AFFILIATION NO. : 2430231 SCHOOL CODE : 15702
PUABAGAN :: DAMODARPUR :: BANKURA
WEST BENGAL :: PIN - 722146**

Divisional Fire Officer
West Bengal Fire & Emergency Services

Signature valid

Digitally signed by JOYDEV
GHOSHAL
Date: 2019.02.02 13:05:09 IST

CONDITION APPLIED FOR FSC/RFSC

1. Maintenance/checking /testing of all fire safety installations shall be checked time to time.
2. Any nominated officer of this Deptt. Shall enter and inspect the building at any time between sunrise to sunset for ascertaining the contravention if any of Fire prevention and fire safety measures.
3. Good housekeeping should be always to be maintained.
4. Mock Drill must be performed twice in a year and recorded properly.
5. To up-keep the Fire Safety Measures of the aforesaid building the following safety measures are to be incorporated:-
 6. Driveway must be free of any type of obstruction for easy movement of Fire Appliances.
 7. No parking will be allowed on the Driveway.
 8. The interior finish decoration of the building shall be made with low flame spread material confirming to the I.S. Specification.
 9. To eliminate risk of fire hazards, good house-keeping both for inside and outside of the building shall be strictly maintained.
 10. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them , particularly lines above false ceiling and ducts.
 11. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable of the building.
 12. The employees and security staffs shall be conversant with installed Fire Fighting Equipments of the building and to operate in the event of Fire and Testing.
 13. Mock Fire practice and Evacuation Drill shall be performed periodically with participants of all the occupants of the building.
 14. Switch gear room shall be protected with automatic CO2 or D.C.P. Fire Extinguishers confirming I.S. specification.
 15. A crew of trained Fire Man under an experience officer shall be maintained round the clock for safety of the building.
 16. First-Aid Fire Fighting system shall be provided as per I.S. specification.
 17. Arrangement shall have to be made for regular checking, testing and maintenance of all the fire fighting installation in the building to keep them in perfectly good working condition at all the times.

18. If required the old lines shall have to be replaced with new lines, the cable shall always be laid in M.S. conduit pipes continuously bonded with the earth.

19. Electrical ducts shall be sealed vertically and horizontally at each floor level by fire resisting materials. (If any)

20. Periodical flashing of water from the Hydrant and Sprinkler pipe lines shall be made to maintain the efficient working performance of above mentioned system.

21. The Fire Check Door shall be sealed with rubber sealing properly in order to prevent the percolation of smoke.

22. The Fire Safety Audit to be conducted a regular interval and to be recorded in the fire prevention maintenance register.

23. Another stair case shall be made positively in case of emergency evacuation.

24. Violation of any recommendations which issued from this office previously this fire safety certificate shall be treated as cancelled

25. This certificate shall remain valid upto three years as per latest GOVT Notification in 2017. Page 1 of 2 Divisional Fire Officer West Bengal Fire & Emergency Services


PRINCIPAL
SARASWATI DEVI INTERNATIONAL SCHOOL
AFFILIATION NO. : 2430231 SCHOOL CODE : 15702
PUABAGAN :: DAMODARPUR :: BANKURA
WEST BENGAL :: PIN - 722146


SCHOOL MANAGER
SARASWATI DEVI INTERNATIONAL SCHOOL
AFFILIATION NO. : 2430231 SCHOOL CODE : 15702
PUABAGAN :: DAMODARPUR :: BANKURA
WEST BENGAL :: PIN - 722146